

OUTAGE REPORT

Outage ID: 72570
 Outage Type: Unplanned
 Outage Status: Ongoing
 Duration: 5 Days

Current Kick-Off Date: **08/01/2008**
 Current Completion Date: **08/05/2008**
 Previous Kick-Off Date:
 Previous Completion Date:
 Last Change Date: 08/04/2008

Comments: Boiler tube leak

Four Corners Power Station - Four Corners 04

Unit ID: 1007555	Capacity: 755 MW
Unit Type: Steam Turbine	Power Usage: Base Load
Unit Status: Operational	Heat Rate: 9,654 btu/kWh
Primary Fuel: Coal Subbituminous	Startup Date: 07/01/1969
Secondary Fuel: Natural Gas	Shutdown Date:
Turbine Manufacturer: GE Energy	Turbine Information: Condensing Cross Compound
Boiler Manufacturer: Babcock & Wilcox	Boiler Information: Supercritical Opposed-Fired LNB BAG FGD-DS

Plant Information

Plant ID: 1523368	Physical Address: County Road 6675
Owner Name: Southern California Edison Company	Fruitland, New Mexico 87416
Plant Name: Four Corners Power Station	Country: U.S.A.
Parent Company Name: Pinnacle West Capital Corporation	Phone/Fax: (505) 598-8100 / (505) 598-8237

Plant Standard Contacts

Title	Contact	QC Date	Telephone	On-Site	E-Mail
Plant Manager	Dave Saliba	Oct-2007	(505) 598-8100 209	Yes	david.saliba@aps.com
Maintenance Manager	Ed Jackson	Jul-2008	(505) 598-8100 376	Yes	edmond.jackson@aps.com
Purchasing Manager	Carla Erickson	Oct-2007	(505) 598-8469	Yes	carla.erickson@aps.com
Engineering Manager	David Bloomfield	Aug-2008	(505) 598-8100	Yes	
Environmental Manager	Richard Grimes	Mar-2008	(505) 598-8100	Yes	richard.grimes@aps.com
Safety Manager	Neil Tribbett	Oct-2007	(505) 598-8100	Yes	neil.tribbett@aps.com
Utility Manager	Ed Jackson	Oct-2007	(505) 598-8100 376	Yes	edmond.jackson@aps.com
IT Manager	Barbara Redel	Oct-2007	(602) 250-1000	No	barbra.redel@aps.com
HR Manager	Shelly Schaffer	Mar-2008	(602) 250-2101	No	shelly.schaffer@aps.com
Security Manager	Robert Parrish	Mar-2008	(602) 250-1000	No	robert.parrish@aps.com